

TEST CERTIFICATE

**for determination of slip resistance
according to DIN EN 16165, Annex B**

Tested material: **Wood/wood composite material**

Material type (wood): oak planks with factory-applied finish
Article description: Special Wood Oil
Dimensions: test sample 1000 x 500 x 15 [mm]
Colour: light oak; finish: colourless (0110) – other colours available on request
Surface: as specified: oiled (application quantity: 1 litre/12 m²) even, fine rough structured
Producer/Supplier: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Client: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Certificate No.: 105592502.001e

Sample receipt: 05.08.2025

Test date: 06.08.2025

Sampling: Sent by the customer to the research institute


Test method: **DIN EN 16165** (edition 02/2023)
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"
Annex B – Shod ramp test
The sample covering was delivered in a condition ready for testing

Test result: Angle value α_{shod} : **8°**

Assessment: **slip resistance class:** **R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 26.08.2025
Schu/ke

This test certificate is only valid for the above-mentioned test material.
The test certificate is issued for a period of 5 years (based on the test date).
The statement of conformity is based on the binary decision rule according to "ILAC-G8: 09/2019".
Publication and reproduction of the test certificate is only permitted in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

