

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood composite**

Kind of material (wood): oak parquet element with factory care
Article no.: 0110 wood special oil
Dimensions: oak planks: length variable, width 145 mm
(cover width 140 mm);
test specimen 1000 x 500 x 14 [mm]

Colour: oak – light
Surface: according to specification: factory oiled, flat,
fine-rough structured

Producer/supplier: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Client: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Certificate No.: 91352002.001e

Test date: 14.08.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property -
Workrooms and fields of activities with slip danger - Walking method - Ramp test"
The sample covering was delivered in a surface condition ready for testing.
Test direction parallel to the grain/board length


Test result: Average total acceptance angle: **9,9°**

Assessment: **Classification group of anti-slip property: R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltekemeyer

Großburgwedel, 18.08.2020
Schu/ed



This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

im Langen Felde 4, 30938 Burgwedel · Telefon (051 39) 99 82-0 · Telefax (051 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-16372-01-00
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EII-BauPVO notifizierte Stelle NR 1212

