

# TEST CERTIFICATE

for the slip resistance of floor coverings  
according to DIN EN 16165, Annex B

Tested material: **elastic coating**

Article description: plastic flooring with factory coating  
Article number: 9600 / 9608 / 9616  
Kind of material: 2K PU Elastic (9600) + Hardener 2K (9608)  
+ Additive Anti-Slip (9616) - Application rate: 80-120 g/m<sup>2</sup>  
Dimensions: variable length and width, d = 1.5 [mm]  
Colour: flooring: white/brown wood plank imitation; coating: matt  
colourless - other gloss levels available on request  
Oberfläche: eben, matt  
Surface: even, matt  
Producer/Supplier: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Client: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Certificate No.: 98392202.001e

Sample receipt: 24.11.2022

Test date: 29.11.2022

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 16165** (edition 12/2021)  
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"  
**Annex B** – Shod ramp test  
The sample covering was delivered in a surface condition ready for testing.

Test result: Angle value  $\alpha_{\text{shod}}$ : **16°**

Assessment: **slip resistance class:** **R10**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 01.12.2022  
Schu/ke

This test certificate is only valid for the products tested an identical with the test sample. No measurement uncertainties are taken into account for the classification according to the test basis. The test certificate is issued for a period of 5 years (related to the test date). Publication and duplication of the test certificate is only permitted in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

