

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood material**

Kind of material: oak parket element with factory-made treatment
Article description: Ecoline Hartwachsöl
Article No.: 3600Eco
Dimensions: oak plank: length variable, width 187 mm (coverage width 180 mm); test specimen 1000 x 500 x 15 [mm]
Colour: colourless; oak brown
Surface: according to statement: grinded, factory-made oiled
- 2 applications (consumption ca. 35 m² per liter / even, fine raw structured)
Addition: coating system: final grinding of wood: abrasive paper graining P120-150; 1st coating: 3600Eco Ecoline Hartwachsöl (15 g/m²) - coverage with double blade scraper; drying 3-5 hours; partial grinding: Mono disc machine with green pad; 2nd covering 3600Eco Ecoline Hartwachsöl - coverage with double blade scraper; drying 3-5 hours
Producer/supplier: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Client: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Certificate No.: 81971701.001e

Test date: 17.01.2018

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property - Workrooms and fields of activities with slip danger - Walking method - Ramp test"
Delivery of the test material has been effected in ready-to-test surface condition.

Test result: Average total acceptance angle: **8,2°**

Assessment: **Classification group of anti-slip property: R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director

F. Höltkemeyer
Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 26.01.2018
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



- Institut für Wand- und Bodenbeläge -
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de

Anerkannte Prüf-, Zertifizierungs- und Überwachungsstelle d. DIBT und DIN CERTCO, Berlin · Notifizierte Prüfstelle der Kommission der EU, Brüssel, Kenn-Nr. 1212