

TEST CERTIFICATE

for the slip resistance of floor coverings
according to DIN EN 16165, Annex B

Tested material: **Wood/wood composite**

Type of material (wood) Finished parquet with factory treatment
Article description: Single Top Oil Care Matt colourless
Dimensions: Wood planks: Variable length, width 145 mm
(top width 130 mm); test sample 1000 x 500 x 13.6 [mm]
Color: planks: Wood grain brown; finish: Matt colorless (4639);
other gloss levels and color shades available upon request
Surface: according to specification: factory-oiled (application
quantity 15-20 g/m²) even, fine-rough structured (wood
grain structure), matt
Producer/supplier: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Client: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Certificate No.: 97302201.001e

Test date: 06.05.2022

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 16165** (edition 12/2021)
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"
Annex B – Shod ramp test
The test material was delivered in a ready-to-test surface condition.

Test result: Angle value α_{shod} : 7°

Assessment: **slip resistance class:** R9

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 10.05.2022
Schu/ke

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –

SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00
aufgeführten Bereiche. Vom DIBT nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

