

TEST CERTIFICATE

for the slip resistance of floor coverings
according to DIN EN 16165, Annex B

Tested material: **Wood/wood composite**

Type of material (wood) Finished parquet with factory treatment
Article description: Single Top Oil (2K) + Single Top Oil Hardener 2K (4643)
Dimensions: Wood planks: Length variable, width 145 mm (deck width 140 mm); test sample 1000 x 500 x 14 [mm]
Color: Planks: Wood grain light brown; finish: Extra white (4608) - other colors available on request
Surface: according to specification: factory-oiled (Application quantity: 15 g/m²) even, fine-rough textured (wood grain structure)
Producer/supplier: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Client: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Certificate No.: 97112201.001e

Test date: 06.05.2022

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 16165** (edition 12/2021)
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"
Annex B – Shod ramp test
The test material was delivered in a ready-to-test surface condition.
Test direction: parallel to the grain

Test result: Angle value α_{shod} : **8°**

Assessment: **slip resistance class:** **R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 10.05.2022
Schu/ke

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

