

# TEST CERTIFICATE

## Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood composite**

Kind of material (wood): oak parquet element with factory care  
Article no.: 8100 care wax  
Dimensions: oak planks: length variable, width 145 mm  
(cover width 140 mm);  
test specimen 1000 x 500 x 14 [mm]

Colour: oak – light  
Surface: according to specification: factory waxed, flat,  
fine-grained structured

Producer/supplier: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Client: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Certificate No.: 91352001.001e

Test date: 14.08.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)  
"Testing of floor coverings - Determination of the anti-slip property -  
Workrooms and fields of activities with slip danger - Walking method  
- Ramp test"

The sample covering was delivered in a surface condition ready for testing.

Test direction parallel to the grain/board length

Test result: Average total acceptance angle: **8,9°**

Assessment: **Classification group of anti-slip property: R9**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 18.08.2020  
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date).  
Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannt und nach EU-BauPVO notifizierte Stelle NB 1212.

