

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood composite material**

Kind of material (wood): oak planks with factory care
Article description: Ecoline Pflegewax / Ecoline Wax Care
Article No.: 8119Eco
Dimensions: oak planks: length variable, width 185 mm
(deck width 180 mm);
test specimen 1000 x 500 x 15 [mm]

Colour: planks: oak - brown; maintenance: colourless,
other colours are available on request

Surface: according to specification: waxed at the factory
(consumption according to technical data sheet:
ca. 1 litre/200 m²), even, fine-rough structured
(wood grain structure)

Producer/supplier: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Client: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Certificate No.: 92582001.001e

Test date: 09.12.2020

Sampling: Sent by the customer to the research institute

Test method: DIN 51130 (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property -
Workrooms and fields of activities with slip danger - Walking method - Ramp test"
The delivery of the test material took place in ready-to-test surface condition.
Test direction: planks lengthwise/parallel to the grain

Test result: Average total acceptance angle: **8,9°**

Assessment: Classification group of anti-slip property: **R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 16.12.2020
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



- Institut für Wand- und Bodenbeläge -

SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langan Felde 4, 30936 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAKkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kern-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

