

# TEST CERTIFICATE

## Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood composite material**

Kind of material (wood): oak planks with factory care  
Article description: Ecoline Pflegewax / Ecoline Wax Care  
Article No.: 8119Eco  
Dimensions: oak planks: length variable, width 185 mm  
(deck width 180 mm);  
test specimen 1000 x 500 x 15 [mm]  
Colour: planks: oak - brown; maintenance: colourless,  
other colours are available on request  
Surface: according to specification: waxed at the factory  
(consumption according to technical data sheet:  
ca. 1 litre/200 m<sup>2</sup>), even, fine-rough structured  
(wood grain structure)

Producer/supplier: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Client: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Certificate No.: 92582001.001e

Test date: 09.12.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)  
"Testing of floor coverings - Determination of the anti-slip property -  
Workrooms and fields of activities with slip danger - Walking method - Ramp test"  
The delivery of the test material took place in ready-to-test surface condition.  
Test direction: planks lengthwise/parallel to the grain

Test result: Average total acceptance angle: **8,9°**

Assessment: **Classification group of anti-slip property: R9**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Hötkemeyer



Großburgwedel, 16.12.2020  
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



- Institut für Wand- und Bodenbeläge -

**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkks akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BaupVO notifizierte Stelle NB 1212.

