

# TEST CERTIFICATE

for the slip resistance of floor coverings  
according to DIN EN 16165, Annex B

Tested material: **Wood/wood composite**

Kind of material (wood): prefabricated finished parquet with factory wipe care  
Article description: wash care oil  
Dimensions: wooden planks: length variable, width 147 mm  
(cover width 131 mm); test sample 1000 x 500 x 15 [mm].  
Colour: planks: wood grain brown; wipe-care oil application: colour-  
less silk matt, colourless; other gloss levels and colour shades  
are available on request  
Surface: according to specification: factory-oiled  
(consumption: 1 litre = ca. 100 m<sup>2</sup>), even, fine-rough  
structured (wood grain structure), matt  
Producer/supplier: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Client: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Certificate No.: 98922301.001e

Sample receipt: 10.01.2023

Test date: 24.01.2023

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 16165** (edition 12/2021)  
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"  
**Annex B** – Shod ramp test


The sample covering was delivered in a surface condition ready for testing.

Test result: Angle value  $\alpha_{\text{shod}}$ : **10°**

Assessment: **slip resistance class: R10**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
p.p. Dipl.-Ing. Peter Schuster



Großburgwedel, 30.01.2023  
Schu/ke

This test certificate is only valid for the products tested an identical with the test sample. No measurement uncertainties are taken into account for the classification according to the test basis. The test certificate is issued for a period of 5 years (related to the test date). Publication and duplication of the test certificate is only permitted in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

