

# TEST CERTIFICATE

for the slip resistance of floor coverings  
according to DIN EN 16165, Annex B

Tested material: **elastic coating**

Article description: plastic flooring with factory coating  
Article number: 9600 / 9608  
Kind of material: 2K PU Elastic (9600) + Hardener 2K (9608)  
Dimensions: variable length and width, d = 1.5 [mm]  
Color: flooring: white/brown wood plank imitation;  
coating: matt colourless - other gloss levels available  
on request

Surface: even, matt  
Producer/Supplier: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Client: SAICOS COLOUR GmbH  
Carl-Zeiss-Straße 3  
48336 Sassenberg

Certificate No.: 97962201.001e

Sample receipt: 02.09.2022

Test date: 23.09.2022

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 16165** (edition 12/2021)  
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"  
**Annex B** – Shod ramp test

The sample covering was delivered in a surface condition ready for testing.

Test result: Angle value  $\alpha_{\text{shod}}$ : **6°**

Assessment: **slip resistance class:** **R9**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 27.09.2022  
Schu/ke

This test certificate refers to the tested specimens. No measurement uncertainties are taken into account for the classification according to the test basis. The test certificate is issued for a period of 5 years (related to the test date). Publication and duplication of the test certificate is only permitted in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E. V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

