

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood composite**

Article designation
(wood) Oak parquet element with factory sealing
(1-component sealant on PU basis)

Article short text: Ecoline MultiTop

Article-No.: 9990Eco - colourless, silk matt

Dimensions: Oak floorboards: length variable, width 145 mm
(cover width 140 mm); test specimen 1000 x 500 x 14 [mm]

Colour: oak - light, silk matt, other gloss levels are available on request

Surface: according to specification: factory sealed (application 3 coats
with intermediate sanding, application rate: 100-120g/m²); even,
fine-rough textured

Addition: Coating structure: 9990 Eco +10% 9908 Eco (hardener) +
10% 9916 ECO (AntiSlip)

Producer/Supplier: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Client: SAICOS COLOUR GmbH
Carl-Zeiss-Straße 3
48336 Sassenberg

Certificate No.: 89222001.001e

Test date: 11.02.2020

Sampling: Sent by the customer to the research institute


Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property -
Workrooms and fields of activities with slip danger - Walking method - Ramp test"
The delivery of the test flooring was carried out in a surface condition ready for testing.
Test direction: parallel to the grain

Test result: Average total acceptance angle: **18,3°**

Assessment: **Classification group of anti-slip property: R 10**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 14.02.2020
Schu/pp

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (051 39) 99 82-0 · Telefax (051 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

